



## UNIDO CLARIFICATION NOTE No. 1

06 March 2025

### UNIDO REQUEST FOR PROPOSAL (ITB)/RFx No. 7000007553 Establishment of one or more LTAs for the supply of RAC equipment required for various Montreal Protocol Projects

Please find below technical questions raised by potential bidder(s) and UNIDO's replies thereto.

Question	Answer
1. Which INCOTERMS the prices have to be quoted. Is it the EXW or FCA (Supplier warehouse)? If DAP, please let us know the delivery address.	1. All required items are to be quoted based on EXW (ExWorks) Incoterms 2020. - Transportation costs are not to be included in the financial proposal. Transportation costs to final delivery at each relevant Delivery at Place (DAP) named UNIDO Project Site will be requested by UNIDO with each individual call-off at later stage. - In addition, UNIDO may at its sole discretion engage another freight forwarder for the delivery of the Equipment from the company or manufacturer site to the relevant DAP named UNIDO Project Site (INCOTERMS 2020).
2. Please provide following clarifications: - Item 150: Charging stations -> could you kindly elaborate on this? Filling stations for non-flammable refrigerants? If so, what kind of specs?  - Item 176: Spare parts for Ultima ID and ID pro -> the manufacturing of these units has been discontinued (circa two years ago)  - Item 188: Hand-held diagnostic tools -> what kind of diagnostics exactly?  - Item 194: Electrical measurement and analyzers -> what kind of equipment exactly?  - Item 199: Possible a typo and not an item?	2. Please note following: - Item 150: Charging system/Refilling stations of for A2L blends. Please refer to 149B. - ISO817, US ASHRAE 34 and EN378 compliant  - Item: 176: please provide specifications and quotation for a replacement product (with similar functionality in 176E  - Item 188: A digital diagnostic that detects the ff in gases, coolant levels , contaminants, antifreeze, and leaks - Item 194: A multimeter, that detects: - Measure voltage, current, resistance, and temperature at various points  - Item 199: Domestic, commercial and industrial refrigeration training boards – for modelling demo
3. Please find attached <b>revised Appendix 1 – Technical Specifications</b> , considering payment terms	
4. Please find attached <b>revised Appendix 3b – Detailed Bid sheet for commercial proposals, to be used when submitting commercial proposal</b>	
5. When shipping the proposal, please include following text for marking of the envelopes: <b>'documents-general business' and state zero value'</b>	
Submission deadline is <b>09 April 2025 16:00 Vienna CET</b>	